

## DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)

Public Health Engineering Department

P.H. DIVISION, GAYA

## Physico-Chemical &amp; Bacteriological Examination Report of Drinking Water Sample of Gaya

Sample Received on : 05.02.2025									
Sample Collected By	Sec Doon Public School Staff	Location of Source							
SL No		Turb.	TDS	Conductivity	Calcium	Magnesium	Chloride	Fluoride	pH
1	Sec Doon Public School Pandey Parsawan Kashtua Road Gaya	0.43	500	325	268	59.32	29.16	53.98	288
Reporting Date :	10.02.2025	Desirable Limit	1.00 NTU	—	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)
		Permissible Limit in absence of alternate source (IS:10500:2012)	5.00 NTU	—	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)
					600 (mg/l)	200 (mg/l)	100 (mg/l)	600 (mg/l)	1500 (mg/l)
							NR	NR	-ve

\*NR-No Relaxation.

जल नमूना का संग्रह हिनाक १०.२.२१  
 See Doon Public School के हारा किया गया है।

P.H. Division,Gaya


 10.2.21  
 Chemist